IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 202504

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636-37-8141

APPLICANT: RHG Indoor Vehicle Storage APPLICANT ADDRESS: 800 McKendree Rd Mooresville NC 28117

SITE ADDRESS: 120 Fast Ln PHONE: 704-651-8613 ALT. PHONE:

SITE DIRECTIONS: Brawley Sch Rd, TL on Stutts Rd, TR on Fast Ln, Lot on R

SUBDIVISION: Brawley Road Business Park SECTION: LOT # 3A LOT AREA: 0.94 ac DESIGN FLOW: 250 gpd L.T.A.R.: 0.25

Septic Tank 1000 (gal) STB 794 Date 8-11-14
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 6 Linear Ft: 255'
Trench Width 36" Max. Trench Bottom Depth * 30"-34" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: Gravity 25% Reduction
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☐ Residence ☐ Business ☑ Other ☐ Slab ☐ Basement w/plumbing
No. Bedrooms No. Persons No. Employees ☐ Crawl Space ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions: * Per Design
- Smooth terrace area at lower edge of drainfield area to allow surface water runoff

INITIAL SITE SKETCH

SEE DESIGN BY ROLLANS SOIL & ENVIRONMENTAL SERVICES (Dated 7-25-14, Approved 8-4-14)

AS BUILT SKETCH

INSTALLED AS SHOWN ON PLAN 3A

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 8/6/14 Installed by: ABERNATHY

IMPROVEMENT PERMIT by: Date: 8-4-14 OPERATION PERMIT by: Date:

AUTHORIZATION TO CONSTRUCT by: Date: 8-6-14 Existing System Inspected by: Date:

APPROVED SEP 18 20

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK