DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Niblock APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9-4-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 63 Edgewater Park PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTA
1		0-9	WK fSBK brn SL/scl	fr sss p					.3
		9-25	MK fSBK RC	fr sss p SSP					
		25-46	WK fSBK yRCl	fr sss p					
2		0-8	gr SL	fr					.3
		8-22	MM SBK RC	fr sss p SSP					
		22-46	WK fSBK yRL	fr sss p few common in SAP					
3	Crest to (B-C)	0-7	gr-WK SBK SL	fr sss p					.3
		7-19	MM SBK RC	fr sss p SSP					
		19-41	WK fSBK yRL	fr sss p common in SAP					
4		0-10	gr-WK SBK brn-RBrn SL/scl	fr sss p					.3
		10-17	MK SBK RC	fr sss p SSP					
		17-39	(Rw) WK fSBK yRCl	fr sss p few common in SAP					
		39-116	WK fSBK massive LSAP	fr sss p					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv 36" Bed	pumped 36" Bed
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DH Hinson
OTHER(S) PRESENT: Wendell Overby