DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Niblock APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 2-16-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 26 Phase 2 Edgewater PK. PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-3	compacted SL	fri-vfi					.3
		3-20	mfsbk LRC	frssp SSXP					
		20-56	wkfsbk RL	frsssp					
2	12% L	0-3	gr drw SL	fr					.3
		3-10	mfsbk RC	frssp SSP			22+ LSAP		
		10-22	(BC) wkfsbk yred	frssp common mottles					
		22-57	wkfsbk-massive LSAP	frsssp					
3		0-19	mfsbk RC	frsssp SSXP					.3
		19-40	wkfsbk RCL	frsssp common red mottles					
		40-60	wkfsbk-massive L/SLSAP	frsssp					
4		0-8	gr drw SL	frsssp					.3
		8-26	mfsbk RC	frssp SSXP					
		26-58	massive L/SLSAP	frsssp w/ few rock					
					Stay 100' from well				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravel Soaked	Same
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: _____
OTHER(S) PRESENT: _____