DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: N. Block — APPLICANT: ___
ADDRESS: ___ — APPLICATION DATE: ___ — DATE EVALUATED: 9-1-04
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): 480 gpd — PROPERTY SIZE: ___
LOCATION OF SITE: Lot 31A Edgewater Park — PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTA
1	10%	0-13	gr, Sdy SL	fr SSS P					.3
		13-44	wk fSbk R cl	fr SSS P					
2		0-15	gr, Sdy SL	fr SSS P					.3
		15-45	wk mSbk R c/cl	fr SSS P, SEXP					
3		0-9	SL/scl	fr SSS P					.3
		9-22	mSbk RC	fr SSS P SEXP					
		22-48	wk fSbk R cl	fr SSS P					
4		0-12	gr, Sdy SL	fr SSS P					.3
		12-27	MSbk RCl	fr SSS P SEXP					
		27-48	wk Sbk ypcl	fr SSS P					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Pm 25% Red	LPP 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS SFE 31A
EVALUATED BY: ___
OTHER(S) PRESENT: ___