IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mady Const. Co. DATE 10-11-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 Ft. On 1112 TR at commodore Water Tank Towards ent on left. S. R. No. _____

SUBDIVISION NAME Marina Village LOT NO. 10 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable ✓	Yes (✓)	No ( )

Lot Area ½ acre

Character & Porosity of Soil Heavy Clay Soils
Percolation Rate 120 minutes/inch
Topography 12% Slope
Depth to Water Table 8' to lake level
Rock or other impervious formations none



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 17"
Water Supply: Individual (✓)
Public ( )

Installed by Ronnie Oaks

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-17-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold