DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Diewst APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 7/15/24
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 13 The Preserve PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	BA TCJ	0-32	gr wk fsbk fr ns sl	fr ss sp					.3
		32-43	m fsbk RC	fr ss sp					
2	14% S-L	0-4	gr fr ns sl	fr ss sp					.3
		4-20	m fsbk RC	fr so sp					
		20-36	wk fsbk yp cl	fr ss sp					
		36-51	wk fsbk massive ls sp	fr ss sp					
3		0-9	gr fr ns sl	fr ss sp					.3
		9-26	m fsbk RC	fr sh sp					
		26-60	wk fr mok fsbk yp cl	fr sh sp common ine sp					
4	#13 TCJ	0-10	gr fr ns sl	fr ss sp					.3
		10-36	m fsbk RC	fr ss sp					
		36-	wk fsbk RCL	fr ss sp few ine sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv 25% Red	Conv pumped 25 50% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature]
OTHER(S) PRESENT: Paul Pennington