...NT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
... OF ENVIRONMENTAL HEALTH
...E WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Diensl Ent. APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 7-16-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 9 The Preserve PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

9A3 0-9 gr brn sl frssp .3
9-53 mSBK rc/fr sssp sap few yb/gr mottles 48"+

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	gr brn sl	fr sss p	few yb/gr mottles, few ind sap	30"+			.25 ≤35"
		6-35	msbk type c	fr sp sap					
		35-50	msbk-Rysd massive	fi sss p	low chy mottles 36"+				
2	#9 TL	0-10	gr brn sl	fr sss p	few gr/brn mottles				.25
		10-29	msbk rc	fr sss p					
		29-48	msbk rc	fr sss p					
3	9A1 18%	0-9	wk sbk brn sl	fr sss p	few ind sap				.3
		9-33	msbk rc	fr sss p sap					
		33-44	msbk rc	fr sss p					
		-57	"	"					
4	9A2	0-5	gr brn sl	fr sss p	common quartz surface coarse fragments				.3
		5-50	msbk rc	fr sss p sap	few mang concretions				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv 25% Red	Rpr 25% Red on 9A
Site LTAR	.25	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS along w/ SFE 9A
EVALUATED BY: _____
OTHER(S) PRESENT: _____