_ _ COUNTY HEALTH DEPARTMENT

APPENDIX H

SITE EVALUATION

(Ground Absorption Sewage Disposal)

OWNER: James Sanders

DATE REQUESTED: 1-19-82

ADDRESS:

PLAT NO.: Lot 3, CC. ~~Estates~~ Coveview Park

COUNTY: Tedell

LOT SIZE: 133X150'

LOCATION OF SITE: 1100 ft 1112 ft 1258 near end of R.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 6-10%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 clay)	S (PS) U clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey soils)	(S) PS U Sub Angular Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	(S) PS 48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, rock)	S (PS) U None 065	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) PS U Few mottles	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S (PS) U 80 mpi	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION*	PS			
SOIL SERIES	Cec. I			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.)

Recommendations/Comments: Public H2O System - / Direct surface H2O away from Nitrification Field

Described By: J. Clemmer

Title: S

Date: 1-19-82

HS Form 2601 (2/77)
Substitution