DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

16

OWNER: Mike Fox APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 12/10/08
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: 1/2 ac
LOCATION OF SITE: Stutts Cove Lot #22 PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed ☆ Head Backhoe Flagged

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-20	Rd/Brn CL	m-w SBK	SS, SP, SE, FF	Rw/few to many SAP lens			PS .3+
		20-48"	SL/C	SAP w SBK	FR				
2		0-8	Brn SCL	GR FR					PS
		8-18	Rd/Brn C/CL	m w SBK	SS, SP, SE, FF-FR				
		18-32	Rd/Brn C	w SBK	w SBK SS, SP, SE, FF	SAP	few to many lenses		.3+ 32"
		32-45	CL/SAP mix						
		45-48	C/SL/SAP mix		Deep trenches?				
3		0-18	Brn SCL	GR FR					PS .2
		18-44	Brn SC/C	w SBK - Mottles	SS, SP, SE, FF/Hard				
			Same Yel/Brn Mottles						
4	AH-1 Initial Septic Area	0-4"	Brn SCL	GR FR					PS .3+ 38"
		4-20"	Rd/Brn C/CL	m-w SBK	SS, SP, SE, FF-FR				
		20-40"	Rd/Brn C	w SBK	SS, SP, SE, FF		w few to many SAP lenses		
		40-45"	Rd/Brn C/SAP mix						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____