DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Fox APPLICANT:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 9/3/02
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
LOCATION OF SITE: Stotts Cove Lot # 37 Stotts Cove PROPERTY RECORDED:
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other Turbyfill
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-9"	Brn SiL GR FR		F-FP				PS .25
		9-24"	B/Brn L mw SBK S,SSE						
		24-36"	B/Brn C mw SBK S,SSE		F				
		36+ LR"	Sap						
2		0-9"	Brn SiL GR FR		F-FP				PS .3
		9-42"	B/Brn C/L mw SBK S,SSE						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT:

DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 127750
COUNTY: DRAPER

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Joseph Maiello
ADDRESS:
PROPOSED FACILITY: SF PROPOSED DESIGN FLOW (.1949): 480
LOCATION OF SITE: 137 Fubbyfield Rd
WATER SUPPLY: [X] Private [ ] Public [ ] Well [ ] Spring [ ] Other
EVALUATION METHOD: [X] Auger Boring [ ] Pit [ ] Cut

APPLICATION DATE 10/3/05
DATE EVALUATED: 10/28/05
PROPERTY SIZE: .74
PROPERTY RECORDED: 1998

TYPE OF WASTEWATER: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	SS LC 5%	0 - 8	mSBKSCL	VFr SS/SP SoAP		48"			PS .3
		8 - 48	mSBKC	Fr SS/SP SoAP					
2	SS LC 7%	0 - 10	mSBKSCL	VFr SS/SP SoAP	40 - 99% SAP 36"+	48"			PS .3
		10 - 48	mSBKC	Fr SS/SP SoAP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	5	5
System Type(s)	LP PBPS	
Site LTAR	.3	

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature]
OTHER(S) PRESENT:

COMMENTS: