4636-44-1351

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR G & O Contractors DATE 6/8/88 PERMIT NO.

PHONE: Business Home


LOCATION 1100 TL Stutts Rd. TR Fairway Estates
On left S. R. No.

SUBDIVISION NAME Fairway Estates LOT NO. 220 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soil clayey
Garbage Disposal Unit Yes (✓) No ( ) Percolation Rate ~.35 gpd/ft²
Auto. Dishwasher Yes (✓) No ( ) Topography ~2%
Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 4'+
Site Suitable Yes (✓) No ( ) Rock or other impervious formations none observed
Lot Area 20000 ft²

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System FAIRWAY ESTATES NOT TO SCALE

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1029 Linear Ft. 343
Depth of Stone in Lines
Water Supply: Individual (✓)
Public ( )

Installed by F.J. ERVIN

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Andrew C. Pierce

COMMENTS:

CERTIFICATE OF COMPLETION BY Andrew C. Pierce DATE 6/8/88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold