4636 44 3582

08104

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harold Foster Jr. DATE June 8, '89 PERMIT NO.

PHONE: Business Home

LOCATION 1100 TC 1112 (Shutts Rd.) to Fairway Estates
~400' on Right S. R. No.

SUBDIVISION NAME Fairway Estates LOT NO. 233 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ PS Yes (✓) No ( )

Character & Porosity of Soil clay
Percolation Rate no 35
Topography 2-6%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area 20000 ft²+

___ Basement with Plumbing ___ Basement without Plumbing ___✓___ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1050 Linear Ft. 350
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Richard Abernathy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

The proposed / existing Deck addition does not appear to impact the existing septic system.
**NOTE:

IMPROVEMENTS PERMIT BY

Jerry Melville R.S.
Date: 5-2-12
ICHD-Environmental Health Division

COMMENTS:

CERTIFICATE OF COMPLETION BY DATE 6-8-89

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold