DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: APPLICANT:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 11-7-00
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
LOCATION OF SITE: Lot 214 Fairway Est. PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-9	dry moderate fine sandy loam	vfr ss sp					PS .25
		9-37	sc/l gr rc/cl	fi ss sp	few common yellow mottles				.34
		37-64	wk fsbk/gr rc/cl	fi/vfi ss sp					
					Best @ 48" ±				
2		0-8	gr loam sl	fr-fi ss sp					
		8-22	wk fsbk loam sc/cl	fi ss sp					.225-.25
		22-44	sc/l gr rc/cl	fi sp-ss sp	common yellow mottles				.13
		44-64	wk fsbk/gr rc/gr cl	fi ss sp	few mid sap				
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY: DWK
OTHER(S) PRESENT: