DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: N. Block APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 7-1-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: ___
LOCATION OF SITE: lot 34A Edgewater Pk phase III PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTA
1		0-7	gr lSL	FR SSP					.3
		7-22	wk SBK RC	FR SSP STXP					
		22-48	wk SBK RC/L	FR SSP					
2	9% ± S/L	0-8	gr lSL	FR SSP					.3
		8-23	mod SBK RC	FR SSP SXP					
		23-47	wk SBK RC/L	FR SSP					
3		0-10	gr lSL	FR SSP					.3
		10-20	mod SBK RC	FR SSP SXP					
		20-47	wk SBK RC	FR SSP SXP					
4		0-8	gr lSL	FR SSP					.3
		8-20	mod SBK RC	FR SSP SXP					
		20-47	wk SBK VFR C	FR SSP SXP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	pm 25% Reduction	LPP BBR
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: ___
OTHER(S) PRESENT: Wendell Overby