IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dave Clark DATE 3-4-74 PERMIT NO.

PHONE: Business 938-3147 Home

LOCATION 1100 TL on 1112 TR on dirt Rd before water Tank 2nd house on right S. R. No. 1112

SUBDIVISION NAME Surfside Park LOT NO. 259 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 14000

Character & Porosity of Soil gravel clay
Percolation Rate not d taken
Topography 5% slope
Depth to Water Table 10+
Rock or other impervious formations 5 to 15' to bedrock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2 ditches with 2 lines
Sq. Ft. 630 Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hannapohl's Service Co.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: ditches connected by a series of a "Tee" + 2 "Y" placed on a 4'x2' slab

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-4-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold