4.00

09495

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Johnson DATE Feb 1, '89 PERMIT NO.

PHONE: Business Home

LOCATION 1100 TR 1112 (Statts Rd) on Right just past Southwood Dr. S. R. No.

SUBDIVISION NAME Marina Village LOT NO. 54 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	1.35	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	3-8%	
Site ~~Suitable~~ PS	Yes (✓)	No ( )	Depth to Water Table	4'+	
			Rock or other impervious formations	none obs.	

Lot Area 122'x160'

~~Basement with Plumbing~~ ~~Basement without Plumbing~~ Not Basement ✓



1000 p.T.

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1080 Linear Ft. 360
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed Reginald Kelly

IMPROVEMENTS PERMIT BY R. Henson, R.S.

COMMENTS: Follow contour, Trench bottom depth = 30". 2" Sch 40 pumpline; 1¼"-1½" laterals with one 5/32" hole every 5 feet. Pump specs: 20 gal/min at approx. 20' TDH. Two foot pressure head per ditch.

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold