~~4635590402~~ [redacted]

**IREDELL COUNTY HEALTH DEPARTMENT** 4636505452

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros. Builders DATE 5-2-79 PERMIT NO. 118

PHONE: Business _____ Home _____

LOCATION 1100 T.L. on 1112 (Stutts Rd)

S. R. No. _____

SUBDIVISION NAME Marina Village LOT NO. 2 SECTION OR BLOCK NO. _____

Site Address: 108 Baywatch Dr - Mrsvl.


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | |
| Auto. Dishwasher | Yes (✓) | No ( ) | |
| Auto. Wash. Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Character & Porosity of Soil clay loam
Percolation Rate _____
Topography 2%
Depth to Water Table sink.
Rock or other impervious formations none obs.

Lot Area ½ AC. +



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Arnie Duncan for Hope Bros.

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 5-2-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold