DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 26 7A 309
PROPERTY RECORDED: yes (pre 1977)
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

Robert French - owner

APPLICANT: John Craver
ADDRESS: _____ OWNER: _____ AGENT: ✓ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED: July 28, '93
Lot 309, Commodore II PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: 70 x 143
LOCATION OF SITE: 1100, TL 1112 TL Marina Lane on rt - corner w/ Driftwood
WATER SUPPLY: On-Site Well ___ Comm. Well ✓ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-2"	gr / cl	1:1 / fr	—	—	PS	—	.5
		2-18"	sbk / c	1:1 / fi	—	—	PS	—	.4
		18-48	wk sbk / sicl	1:1 / fr	—	—	PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): PS per 1956 SITE LONG-TERM ACCEPTANCE RATE: .03
EVALUATED BY: [signature] OTHER(S) PRESENT: John Craver
COMMENTS: Extremely small available space. This site can be reclassified PS per 1956 - modified system.