IREDELL COUNTY HEALTH DEPARTMENT

12583

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Hunt DATE March 26, 91 PERMIT NO. 26-7-A-242

PHONE: Business _____ Home _____

LOCATION 1100 ft 1112 (Statts Rd.) on right corner lot w/ Marina Lane S. R. No. _____

SUBDIVISION NAME Commodore Peninsula LOT NO. 242 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 ~~3~~ 4/1/91 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	ps clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	3, 4	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2b	
Site ~~Suitable~~ PS	Yes ( )	No ( )	Depth to Water Table	4ft	
			Rock or other impervious formations	none obs.	

Lot Area ~76' x 140' Existing lot

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals. DCH

Nitrification Field: 4/1/91

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200 *

Depth of Stone in Lines 12" 16" DCH

Water Supply: Individual ( ) penalty gravity flow

Public (✓) cw

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Ray N. Hunt

D-box w/ speed levelers

IMPROVEMENTS PERMIT BY David R. Hinson, EHC

COMMENTS: Pull plumbing out at ground level in order to keep septic system from being too deep. 36" maximum trench bottom depth on all drainfield lines.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold