4636508574

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jimmy Ellis DATE 4-27-22 PERMIT NO. 90

PHONE: Business _____ Home 662-5516

LOCATION 110 Dan Hill Rd off Mocksville Hwy

S. R. No. _____

SUBDIVISION NAME Commodore LOT NO. 5 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 +


Character & Porosity of Soil Clay loam

Percolation Rate 30 Bpi

Topography Slope

Depth to Water Table 18"

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 250'

Depth of Stone in Lines 18"

Water Supply: Individual (✓)

Public (✓)

Installed by E. S. Sain

IMPROVEMENTS PERMIT BY John Hamilton

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hamilton DATE 4-27-22

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold