DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ray Stout APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 8-5-97
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE: 80x193
LOCATION OF SITE: Lot 132 Commodore Pen PROPERTY RECORDED: yes
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (1941) 1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L ~6%	0-8	SAb plowed	fr					PS .3
		8-18	SAb bar e/el	fi sp so/po					
		18-38	SAb RCl	fr ss sp so/po					
		38-48	mk SAb RCl few mi sap	fr ss sp so/po					
2	L ~5%	0-6	SAb plowed	fr					PS .3
		6-18	SAb RCl few co	fi sp so/po					
		18-48	M-WK SAb RCl common mica flakes, few Mn features	fr ss sp so/po					
3									
4	180 350 3-30								

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____