4636509091

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

~~19~~ 19

OWNER OR CONTRACTOR Eugene Upton DATE 2-26-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TL on 1112 to Commodore Penn. Left Past water Tank 2nd lot on left S. R. No. 1112

SUBDIVISION NAME Commodore ~~Estates~~ Peninsula LOT NO. 131 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 16,000 sqfeet

Character & Porosity of Soil Loam Loam Permability Mod to rapid
Percolation Rate 15 min/inch
Topography 2 to 3%
Depth to Water Table 10+
Rock or other impervious formations 5 to 15' to bedrock



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 5625 Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by J.R. Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: Move water line so as to maintain a minimum distance of 10' between it and the septic tank drain field.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 2-26-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold