147 Bluewing Ln.

IREDELL COUNTY HEALTH DEPARTMENT 4636-51-0110

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Henry T. Stevens DATE 12-19-84 PERMIT NO. 465

PHONE: Business _____ Home Stutts

LOCATION 1100 TR 1112 TR Bluewing (Across from H2O TANK) Near Cuyuna on left S. R. No. _____

SUBDIVISION NAME Lakeside Tract LOT NO. 274 SECTION OR BLOCK NO. 2

Commodore Penn

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2


Garbage Disposal Unit Yes ( ) No (X)
Auto. Dishwasher Yes (X) No ( )
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )

Character & Porosity of Soil Clay
Percolation Rate 05 gpf 12-19-84
Topography Gently Sloping
Depth to Water Table 2-8 ft
Rock or other impervious formations None Obs

300 Gal Surge
1000 Gal pump

Lot Area Lot Recorded Prior 1973

(X) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 120 Ft Linear Ft. 24"
Depth of Stone in Lines 1 ft 6 inches

Water Supply: Individual ( )
Public (X)
Commodore H2O

Installed by T. J. Erwin Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY T. Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 12-19-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold