4636-51-0647

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Earl Love DATE 2-21-75 PERMIT NO. 28

PHONE: Business _____ Home 366-1160

LOCATION 1100 Teon 1112

_____ S. R. No. _____


SUBDIVISION NAME Cove View Part LOT NO. 34 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
~~Site Suitable~~ Yes (✓) No ( )
Lot Area 15000 Sq Ft

Character & Porosity of Soil Sandy Clay Loam Fair to Poor
Percolation Rate 10 Fatem
Topography 20 % Slope
Depth to Water Table 10'+
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 270
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by E.J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 2-21-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold