IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gene Grazella DATE 12-4-73 PERMIT NO. 311

PHONE: Business _____ Home _____

LOCATION out 1100 TL on 1112 1mi on right

SUBDIVISION NAME Coveview Park LOT NO. 28 S. R. No. 1112

SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes ( )	No (✓)

Lot Area approx. 15,000 Sq. Feet

Character & Porosity of Soil cecil sandy loam
Percolation Rate not taken
Topography 2 to 6% slope
Depth to Water Table 10'
Rock or other impervious formations large amount of hard bedrock 18" under surface of ground



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4 255
Sq. Ft. 696 Linear Ft. [redacted]
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Field Engineering

IMPROVEMENTS PERMIT BY not issued. Trailer on lot before Oct 1

COMMENTS: lot is very poor for septic tank system. The rock formations underneath ground level could be a serious hazard to the function of this system.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 12-4-73
approved only on construction

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold