IREDELL COUNTY HEALTH DEPARTMENT

Authorization to Construct

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / ~~CERTIFICATE OF COMPLETION~~ / OPERATION PERMIT / EXISTING SYSTEM INSPECT

PROPERTY DESCRIPTION NO. 065672 DATE 8/11/97 TAX MAP NO. 4636512018 Watershed: X Yes ☐

OWNER OR CONTRACTOR Patricia H. MacDonald (BOB STILP) PHONE: Business 595-0555 Home

ADDRESS 1805 Logie Ave Charlotte, NC 28205

LOCATION Brawley TR Stutts TR Blueswing on (L) across from Ensign Rd. 139 Blueswing Ln. (Loop)

SUBDIVISION Commodore Pen. BLOCK / SECTION LOT 271 LOT AREA ~.26 SITE CLASS PS DESIGN FLOW 240 L.T.A.R. 1 (Loop)

Septic Tank: 1000 Gallons; STB 1012 Date 9/7/98

Pump Tank: 1000 Gallons; PT 19 Date 9/6/98

Pump Make: Model Serial No.

Nitrification Field: No. Fields 1 Square Feet 2400 Linear Feet 480

No. Lines 11 Trench Width 18" Max Trench Bottom Depth 13" Gravel Depth

X New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LPP - SHALLOW

Repair System Description:

Maintenance Agreement Required: X Yes ☐ No

X House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2 No. Employees

☐ Slab X Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual X Community ☐ Public

Comments:

Lot platted prior 1/1/83 - Repair area not required

"BOB STILP"

Comments:

Installed per T. Jacobs LPP Plan. - 1/7/99

INITIAL SITE SKETCH

Installation per Toney C Jacobs Consulting Soil Scientist LPP Plan Design -

Very tight situation - dimensions shown on Jacobs site plan are not negotiable.

Do not attempt installation without first acquiring a copy of Jacobs plans and spec. for this system.

AS BUILT SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed: Russell M. Davis

Installed by: Richard Abernathy

Improvement Permit by: Wesley Sparks R.S. date 8/12/97

Certificate of Completion by: Wesley Sparks RS date 1/7/99

Existing System Inspection by: Wesley Sparks R.S. date 8/12/97

Operation Permit by: date

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD