~~4636528~~ 4636512889

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ladimer Malachowski DATE 4-16-80 PERMIT NO. 82

PHONE: Business _____ Home _____

LOCATION 1100 TR 1112 TR 1258 ~.2 mile on left

S. R. No. _____


SUBDIVISION NAME Cove View Park LOT NO. 726+PR SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 Min	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Unknown	
			Rock or other impervious formations	None observed	

Lot Area 15,000 ft



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (X)
Community H2O

Installed by F. J. Emmons

IMPROVEMENTS PERMIT BY David R Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmons DATE 4-16-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold