4636-51-3725

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roy Crosby DATE 4-24-04 PERMIT NO. 160

PHONE: Business _____ Home 528-8427

LOCATION 1100 Flora Hill Rd 1mi TR onto Coreview Park S. R. No. _____

SUBDIVISION NAME Coreview Park LOT NO. 30 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Sandy clay loam (Porosity good)
Percolation Rate Fast to Med
Topography 3% to 8% Slope
Depth to Water Table 10' +
Rock or other impervious formations Bedrock at 5'

Lot Area 4,900 Sq Feet



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 225 Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by J. R. Bowers

IMPROVEMENTS PERMIT BY T. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY T. C. Moore DATE 4-30-04

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold