IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roy Camby DATE 4-24-74 PERMIT NO. 100

PHONE: Business _____ Home 597-7487

LOCATION 1/20 TL on 1112 1mi TR into Coveview Park. S. R. No. _____

SUBDIVISION NAME Coveview Park LOT NO. 30 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	( )	No	(✓)	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 16,000 Sq feet

Character & Porosity of Soil Sandy clay loam (Porosity good)
Percolation Rate Not taken
Topography 2% to 3% slope
Depth to Water Table 10'+
Rock or other impervious formations Bedrock at 5'



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-24-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold