IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Susie Berry DATE 2-6-75 PERMIT NO.

PHONE: Business Home

LOCATION 1100 Tyson Hill

S. R. No.


SUBDIVISION NAME Conover Park LOT NO. 25 SECTION OR BLOCK NO.

House (✓) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1 ½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	Poor-Fair
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60 min/in	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
			Rock or other impervious formations	Some	

Lot Area 125 x 150



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by F.J. Erwin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 3-6-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold