IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tim McManus DATE 2-20-24 PERMIT NO. 259

PHONE: Business _____ Home _____

LOCATION 1st TR on 112 TR on dirt road
1 Lot

SUBDIVISION NAME Deer View Est LOT NO. 23 SECTION OR BLOCK NO. _____

S. R. No. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 44,000

Character & Porosity of Soil Clay loam Moderate
Percolation Rate 1in 25min
Topography 2-3% Slope
Depth to Water Table 10ft
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 525 Linear Ft. 350
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by Owner

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Tim McManus DATE 2-20-24

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold