09284

~200

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Wilson DATE Nov 23, '88 PERMIT NO. 20-13

PHONE: Business _____ Home _____

LOCATION 1100 TR 1112 (Statts Rd.) TR Blowing TR Driftwood ~ 200 on left S. R. No. _____

SUBDIVISION NAME Commodore Pen. LOT NO. 298 & 299 Combined SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms ~ 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS (REAR) Yes (✓) No ( )

Lot Area ~½ Ac

Character & Porosity of Soil clay


Percolation Rate ~ 3

Topography ~ 5%

Depth to Water Table 44

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

1000 pt.

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3-4

Sq. Ft. _____ Linear Ft. 200'87

Depth of Stone in Lines 16" ±

Water Supply: Individual ( ) panels

CW Public (✓) p-d

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: H. D. Christenberry

46 panels total

1 5/32" holes per panel

Two foot pressure head per ditch

IMPROVEMENTS PERMIT BY J. R. Hinson, RS.

COMMENTS: Follow contour with drainfield. Install trenches at a depth of 25" to ditch bottom. Maintain 5' + off Lot Lines with system. Pump 5 pass; 35 gal/min at ~ 21' TDH Dose approx 165 gal per 5 min cycle

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold