IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Burt Bartniski DATE 5-31-74 PERMIT NO. 143

PHONE: Business _____ Home _____

LOCATION 1100 Thon 7112 1mi on right S. R. No. _____

SUBDIVISION NAME Coveview Park LOT NO. 20 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No	(✓)
Auto. Dishwasher	Yes (✓)	No	( )
Auto. Wash. Machine	Yes (✓)	No	( )
Site Suitable	Yes (✓)	No	( )

Lot Area 16000 Sq feet

Character & Porosity of Soil clay loam
Percolation Rate 48 min/inch
Topography 2% slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 300 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Grade lot to keep water from standing on top of drain lines. This is very important.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-31-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold