IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Randy Simpson DATE 3-12-07 PERMIT NO. 48

PHONE: Business _____ Home _____

LOCATION 1100 ft. on 1112 1mi on right

_____ S. R. No. _____

SUBDIVISION NAME Coulview Park LOT NO. 14 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Sandy Clay loam (porosity good)
Percolation Rate Not taken
Topography level to more slope
Depth to Water Table 18"
Rock or other impervious formations None

Lot Area 1 acre to 2 acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 450
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)
Commodore water system
Installed by Julian Bowles and Rob Mason

IMPROVEMENTS PERMIT BY L. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. E. Moore DATE 2-19-07

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold