DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Fox APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 2/17/05
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Stutts Cove Lot #18 (Stutts & Turby Fill) PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Pit	D-6	Bw Scl	GR FR					PS .3+
		6-22	R C/Cl	m-w SBK	SS, SP, SE	FI	FR		
		22-24	R C/Cl	m-w SBK	SS, SP, SE	FI	FR	Hydrous mica SAP Flakes	
		24+	LSAP						
2	AH-1 5%	D-4"	Bw Scl						PS .3
		4-14"	R/Bw C/Cl	m-w SBK	SS, SP, SE	FI	FR	Common Mica Flakes & hydrous mica SAP flakes	
		14-37"	R/Bw C/Cl	w SBK	SS, SP, SE	FI	FR		
		37-48"	R/Bw C/Cl & SAP mix						
3	AH-2 2/17/05	0-10"	Bw Scl	GR FR					PS .3
		10-48"	R/Bw C/Cl	m-w SBK	SS, SP, SE	FI	FR	wp Common Mica Flakes	
			few SAP Inclusions						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____