IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. G. Tomlinson DATE 7-24-04 PERMIT NO. 264

PHONE: Business _____ Home 704-876-3521

LOCATION 150 west TL on 1109 TL TR on 1112 then TR on dirt Rd 1st on right S. R. No. 1112


SUBDIVISION NAME Cooper's Park LOT NO. 6 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2	No. Bathrooms 2		Character & Porosity of Soil	Sandy Clay loam	
Garbage Disposal Unit	Yes ( )	No (✓)	Percolation Rate	20 min 1 in	
Auto. Dishwasher	Yes ( )	No (✓)	Topography	Slo Slope	
Auto. Wash. Machine	Yes (✓)	No ( )	Depth to Water Table	10 ft	
Site Suitable	Yes (✓)	No ( )	Rock or other impervious formations	None	

Lot Area 5 acres +/-

Proposed House



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
- No. of Lines 3
- Sq. Ft. 225 Linear Ft. 250
- Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by E.J. Erwin

IMPROVEMENTS PERMIT BY Johnny Hendrix

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 7-29-04

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold