4636-52-3019 W.G. Isenhower Rt #6 Box 564 -16 Mooresville

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jackie Saunders DATE 9-5-78 PERMIT NO. 51

PHONE: Business _____ Home _____

LOCATION 1100 TL on 1112

S. R. No. _____

SUBDIVISION NAME Coveview Trailer Park LOT NO. 7 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area Existing

Character & Porosity of Soil Existing System
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by _____
Installed 1973

IMPROVEMENTS PERMIT BY _____

COMMENTS: System Work OK at Time of This Inspection

CERTIFICATE OF COMPLETION BY John Houston DATE 9-5-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold