IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert J. Campbell DATE 7-13-78 PERMIT NO. 160

PHONE: Business _____ Home 663-5832

LOCATION 1100 ft on 112

S. R. No. _____

SUBDIVISION NAME Cove View Trailer Court LOT NO. 9 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	( )	No	(✓)	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil Clay loam
Percolation Rate 60 min/in
Topography 2% to Level
Depth to Water Table 10 ft
Rock or other impervious formations None

Lot Area Existing



Plot of System

Size of Tank ~~1000~~ Existing Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Henderson DATE 7-13-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold