DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mike Fox
APPLICANT:
ADDRESS:
APPLICATION DATE:
DATE EVALUATED: 12/8/9
PROPOSED FACILITY:
PROPOSED DESIGN FLOW (.1949):
PROPERTY SIZE:
LOCATION OF SITE: Stutts Cove, Lot #5 Stutts
PROPERTY RECORDED:
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other Turby fill
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10"	Brw SR SiC						PS .3 40 100"
		10-35	Rd/Brw C/c m-w SBK S SP, SE		F-FR				
		35-40	Rd/Brw C/c w SBK S SP, SE		FR w few to mony SAP inclu				
		40+	SAP						
2	L-Toe Side	0-17	Brw SiC						
		17-26	Rd/Brw C/c m SBK S, P, SE		Fi				
		26-40	Rd/Brw C/c w SBK S SP SE		FR w few to mony SAP inclu				
		40-48	SAP						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: