IREDELL COUNTY HEALTH DEPARTMENT 4636-52-7003

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Edward Foster DATE 6-24-80 PERMIT NO. 180

PHONE: Business _____ Home _____

LOCATION 1100 TL 1112 TR 1258 2nd on R

S. R. No. _____


SUBDIVISION NAME Coveview Park LOT NO. 11 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil		
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate		Existing
Auto. Wash. Machine	Yes (X)	No ( )	Topography		
Site Suitable	Yes (X)	No ( )	Depth to Water Table		System
Lot Area Existing			Rock or other impervious formations		

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public (X)

5-30-74

Installed by J. R. Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Existing System Working OK @ date of inspection
Originally installed 5-30-74 - owner should not garden
over system -

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 6-24-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold