IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 135987 PIN# 4636 52 8903 DATE 7/8/06

OWNER OR APPLICANT Pride Homes Inc. PHONE: Business 704-664-1808 Home

ADDRESS 578 Normandy Rd. Mooresville, NC. 28117

LOCATION 1100 Tl Statts Rd on (L) just past Woodstream Rd.

SUBDIVISION Norman Woods BLOCK / SECTION LOT 9 LOT AREA .488Ac SITE CLASS PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB [redacted] Date 2-31-06

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 840 Linear Feet 280

No Lines 8 @ 35' Trench Width 3' Max Trench Bottom Depth 3'

[X] New System [ ] Repair [ ] Expansion System Type: I II (III) IV V VI

System Description: GRAVITY - 16" PPBPS

Repair System Description: < 83 Lot

Maintenance Agreement Required: [ ] Yes [X] No

[X] House/Mod. Home No. Bedrooms 4

[ ] Mobile Home No. Persons

[ ] Business No. Employees

[ ] Other

Water Supply: [X] Individual [ ] Public [ ] Community

Gravel Depth No [X] Gravity [ ] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions: Fast Track by Rollins Soils Environmental Svcs. Flow Diverter and 2 Distribution Boxes required on this system. No Variation from Rollins Design will be approved.

Comments:/Conditions:

INITIAL SITE SKETCH

See Site Plan and Installation Layout by Rollins Environmental Svcs.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [ ] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X Ronnie Bryant date 7/11/06

Improvement Permit by: Wesley Sparks R.S. date 7/8/06

Authorization to Construct by: Wesley Sparks RS date 7/8/06

Installed by: [redacted]

Operation Permit by: Wesley Sparks date 10/11/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK