IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # BP 180831

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4636534344

APPLICANT: TG Custom Homes APPLICANT ADDRESS: 840 Edminston Rd Mt Ulla, NC 28125

SITE ADDRESS: 310 Stotts Rd Mooresville, NC 28117 PHONE: 704724-3111 ALT. PHONE:

SITE DIRECTIONS: Brawley School Rd TL Stotts Rd on right after Turby fill

SUBDIVISION: Stotts Cove SECTION: LOT # 46 LOT AREA: 1 DESIGN FLOW: 480 gpd L.T.A.R.: .3

Septic Tank 1000 (gal) STB Date
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 4 Linear Ft: 400
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: Gravity 25% Reduction LPP BPS
Repair System Description:
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons 4
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions:

INITIAL SITE SKETCH

See Revised Plan
(submitted 2/26/14)
From Michael Athanas
& Assoc.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 3/10/14 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: Date: 3/5/14 OPERATION PERMIT by: Date: 5-14-14

AUTHORIZATION TO CONSTRUCT by: Date: 3/5/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

Scale
1" = 40'

AREA SUMMARY
LOT 46
0.696
30,301
ACRE
SQ.FT.

N24°02'41"W
99.03'

09-35'
P8-68'
W7-99'
R6-55'
05-86'
P4-90'
W3-100.22
B2-100'
R1-110'
35' SETBACK
15' SETBACK
17.0'
56.8'
PROPOSED
SINGLE FAMILY
RESIDENCE
DRIVE
75.0'
35' SETBACK
260.48'
261.84'
N64°45'49"E
S72°09'02"W
Field Staked
House Box
well
C2
3/5/14

STUTTS ROAD
SR# 1112 - 60' PUBLIC R/W
N

48
47
45
80
88
92
112
108
23
28
27
132.62'