DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Michael Fox & Assoc APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 11/24/98
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Shutts Cove Lot # 8 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-48"	Rd/Brn C/Cl m-f SBK w/Some SAP Tailus	SS, SP, SE	FI-FR Starting at 42"				PS 3
2		0-10"	Brn SCL GR FR						PS 1
		10-36"	Rd/Brn C/Cl m-w SBK	SS, SP, SE	FI-FR w/ Yel/Brn Rd. Mottles				
		36-48"	Rd/Brn C/Cl w SBK	SS, SP, SE	FI w/ Yel/Brn Rd. Mottles				
					Try to Keep Trenches Shallow				
3		0-32"	Rd/Brn C/Cl m-w SBK	SS, SP, SE	FR w/ Tailus				PS .3 to 32"
		32-48"	SAP # Cl	mix					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____