IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 135988 PIN# 4636 53 7092 DATE 7/11/06

OWNER OR APPLICANT Pride Homes Inc. PHONE: Business 704-664-1808 Home

ADDRESS 578 Normandy Rd. Mooresville, NC 28117

LOCATION 400 TL Statts on (L) just past Woodstream intersection

SUBDIVISION Norman Woods BLOCK / SECTION LOT 10 LOT AREA .45AC SITE CLASS. DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1012 Date 3-30-06 (Taylorsville)
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 1260 Linear Feet 420
No Lines 8 Trench Width 3' Max Trench Bottom Depth 3

☒ New System ☐ Repair ☐ Expansion System Type: I (II) (III) IV V VI
System Description: Dainty 3507D Recf. <83 L.F.
Repair System Description:
Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons 4
☐ Business No. Employees
☐ Other

Water Supply: ☐ Individual ☐ Public ☐ Community

Gravel Depth No ☐ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Fast Trench Lot by Rollins Soil + Environmental Svcs. Drop Boxes Required
No Modification Possible - Tight Site.

Comments:/Conditions:

INITIAL SITE SKETCH

See Site Plan & Specification Sheets from Rollins Environmental Svcs. Prior to attempting installation.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Ronnie Brown date 7/13/06
Improvement Permit by: Wesley Sparks RS date 7/11/06
Authorization to Construct by: Wesley Sparks RS. date 7/11/06

Installed by: C+S
Operation Permit by: Joh E Alexd date 10/11/06
Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK