3:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 135985 PIN# 4636 53 9083.000 DATE 7/8/06

OWNER OR APPLICANT Pride Homes Inc. PHONE: Business 704-664-1808 Home

ADDRESS 578 Normandy Rd. Mooresville, NC 28117

LOCATION 1100 Tl Stutts Rd. Tl Woodstream on (R) at intersection of new road (Woodstream Dr.)

SUBDIVISION Norman Woods BLOCK / SECTION LOT 58 LOT AREA .542 SITE CLASS. P3 DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1013 Date 5-16-06
Pump Tank: Gallons; PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 810 Linear Feet 270
No Lines 6 @ 45' Trench Width 3 Max Trench Bottom Depth 3'

[X] New System [ ] Repair [ ] Expansion System Type: I II (III) IV V VI
System Description: Gravity - 16" APBPS
Repair System Description: Y < 83 LOT
Maintenance Agreement Required: [ ] Yes [X] No

[X] House/Mod. Home [ ] Mobile Home [ ] Business [ ] Other
No. Bedrooms 4 No. Persons No. Employees

Water Supply: [X] Individual [ ] Public [ ] Community

Gravel Depth No [X] Gravity [ ] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments:/Conditions: Fast Track by Rollins Soil + Environmental Services. Flow Divider and 2 Distribution Boxes required on this system. No Variation will be Approved on this installation.

INITIAL SITE SKETCH

See Site Plan and Installation Layout by Rollins Environmental Svcs.

Comments:/Conditions: 2ft wide x 87ft long part of driveway on LOT 57 encroaches on this LOT, 58 from the N.E. Iron at the road. This encroachment does not effect this lots septic system

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [ ] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Ranie Browne date 7/11/06

Improvement Permit by: Wesley Sparks RS. date 7/8/06

Authorization to Construct by: Wesley Sparks RS date 7/8/06

Installed by: C+S Grading

Operation Permit by: John E. Clark date 11/15/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK