DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: N. Block — APPLICANT: _____
ADDRESS: _____ — APPLICATION DATE: _____ — DATE EVALUATED: 9-3-04
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): 480 gpd — PROPERTY SIZE: _____
LOCATION OF SITE: Lot 53A Edgewater Park — PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4%/0 V	0-6	gr brnsl	fr sss p					.3
		6-27	mtsbk rd	fr sss p					
		27-36	wkfsbk rc	fi sp sop					
		36-58	wkfsbk rcl	fr sss p					
2		0-9	gr brnsl	fr sss p					.3
		9-19	mtsbk rc	fr sss p sop					
		19-41	wkfsbk rc	fi fr sp sop					
		41-57	wkfsbk rl	fr sss p					
3		0-13	gr brnsl/scl	fr sss p					.3
		13-52	wkfsbk elbrn-r cl/cl	fr sss p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	pm25 Rd	LPP-50 Rd.
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: _____
OTHER(S) PRESENT: _____