IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Claude Bumgardner DATE 2-6-74 PERMIT NO. 12

PHONE: Business _____ Home _____

LOCATION Rd 1100 Th on 1112 To Commadore Penn.

SUBDIVISION NAME Commodore Penn. LOT NO. 203 + 214 SECTION OR BLOCK NO. _____ S. R. No. 1115


House ( ) Mobile Home ( ) Business ( ) Other modular Home

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area ½ acre

Character & Porosity of Soil Cecil Sandy loam
Percolation Rate Not taken
Topography 2 to 5 slope
Depth to Water Table 10+
Rock or other impervious formations 5 to 15 to bedrock



Plot of System

Size of Tank 1500+ Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 2-6-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold