4636619050

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Earl Allison DATE Jan. 4, '80 PERMIT NO. 1

PHONE: Business _____ Home _____

LOCATION 1100 Th on 1102 Th on 1283 ~.2mi on Rt.

S. R. No. _____


SUBDIVISION NAME Norman Shores LOT NO. 6 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ~20,000ft²

Character & Porosity of Soil clay loam
Percolation Rate 80 mpi
Topography 8-10%
Depth to Water Table 6'+
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Richard Abernathy

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE Jan 4, 80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

9:30

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Earl Dixon DATE 10/24/79 PERMIT NO. 325

PHONE: Business _____ Home _____

LOCATION 1490 TL on 1112 TL on 1283 ~ .2mi on Right

S. R. No. _____

SUBDIVISION NAME Norman Shores LOT NO. 6 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area ~20,000 ft²

Character & Porosity of Soil clay loam
Percolation Rate 50 mpi
Topography 8-10%
Depth to Water Table 6'+
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1000 Linear Ft. 333
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY David R. Hanson

COMMENTS: May have to use 12'x84' w/ 16" of stone if you can't get the single trenches in.

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold