DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

13694(6

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Carolina Builders
ADDRESS: _____
PROPOSED FACILITY: House
LOCATION OF SITE: Forman Woods

APPLICATION DATE 7-26-06
DATE EVALUATED: 7-26-06
PROPERTY SIZE: .5
PROPERTY RECORDED: _____

PROPOSED DESIGN FLOW (.1949): 480

WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____

EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	SCWSBK	SSSPSEP					PS .3
		6-[illegible]	CWSBK	SSSPSEP					
2		0-8	SLWSBK	SSSPSEPK					PS .3
		8-38	CLWSBK	SSSPSEPK					
		38+48	SCWSBK	SSSPSEP					
3		0-8	SLWSBK	SSSPSEPK					PS .3
		8-48	SCWSBK	SSSPSEPK					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	100% 2767	
System Type(s)	50% Lat Pl	
Site LTAR	.3	

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: RS Kellycox
OTHER(S) PRESENT: _____

COMMENTS: _____