DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

136944
4/036625038

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Carolina Builders
ADDRESS: _____
PROPOSED FACILITY: House
PROPOSED DESIGN FLOW (.1949): 48
LOCATION OF SITE: Norman Woods

APPLICATION DATE _____
DATE EVALUATED: _____
PROPERTY SIZE: 1.401
PROPERTY RECORDED: _____

WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	C w SBL	SSSPSeP		52			.3
		6-40	C w SBL	SSSPSeP					
		40-52	C w SBL	SSSPSeP					
2		0-9	SC w SBL	SSSPSeP		52			.3
		9-52	C w SBL	SSSPSeP					
3		0-12	SC w SBL	SSSPSeP		52			3
		12-52	C w SBL	SSSPSeP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	100/20	
System Type(s)	LPP Pmp	
Site LTAR	.3	

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): BG
EVALUATED BY: Kurt Cox
OTHER(S) PRESENT: _____

COMMENTS: _____